



DECLARATION OF TYPE TEST

We **Novar ED&S Limited (MK Electric)**

Of The Arnold Centre, Paycocke Road, Basildon, Essex, SS14 3EA

Declare under our sole responsibility that the following products :-

Ega Mini Surface Accessory Boxes

List nos.	ESU/23/1	1 gang, 25mm deep, one entry (centre top)
	ESU/23/1/1	1 gang, 25mm deep, one entry (side)
	ESU/23/2/3	2 gang, 25mm deep, three entries (top and both sides)
	ESU/35/1/1	1 gang, 32mm deep, one entry (centre top)
	ESU/35/2/3	2 gang, 32mm deep, three entries (top, bottom and side)
	ESU/22/1/1	1 gang, 25mm deep, one entry (side)
	ESU/25/1/2	1 gang, 25mm deep, two entries (top and bottom)
	ESU/22/2/3	2 gang, 25mm deep, three entries (top and both sides)
	ESU/25/2/3	2 gang, 25mm deep, three entries (top and bottom)
	ESU/27/1/3	1 gang, 32mm deep, three entries (top and bottom)
	ESU/27/2/1	2 gang, 32mm deep, one entry (top)
	ESU/44/2/3	2 gang, 44mm deep, three entries (top and both sides)
	ESU/32/1/40	1 gang, to fit 40 x 16mm trunking, two entries
	ESU/32/2/25	2 gang, to fit 25 x 16mm trunking, two entries
	ESU/32/2/40	2 gang, to fit 40 x 16mm trunking, two entries

To which this declaration relates are in conformity with the test requirements of :-

BS 4662:1970
Boxes for the enclosure of electrical accessories
Clauses 1.4, 1.6, 1.7, 1.8, 1.9

And on the basis of this testing, these products are considered to comply with the essential requirements of the following
EU directive: Low Voltage Directive (2006/95/EC)

Support documentation reference :- 9807016B

Document reference no. :-

DT0115.2

Date of Issue :-

4th January 2007

Technical Manager (Cable Management)

MK Electric
Novar ED&S Limited
Registered Office: Honeywell House, Arlington Business Park, Bracknell, Berkshire RG12 1EB

