

DC1124.1

Created on 22/12/2010 09:27:00



DECLARATION OF CONFORMITY

We **Novar ED&S Ltd (MK Electric)**
of **The Arnold Centre, Paycocke Road, Basildon, Essex. UK. SS14 3EA**

Declare under our sole responsibility that the following products:

Masterseal Plus Ingress Protected Socket-Outlets, 250V a.c., 13A

List No.	Description
K56480 GRY/WHI/BLK	1 gang, Unswitched, IP66, IK10
K56486 GRY/WHI/BLK	1 gang, Switched, IP66, IK10

To which this declaration relates, are in conformity with the test requirements of the following standards:

BS EN 60529:1991 Degrees of protection provided by enclosures (IP code)

BS EN 62262:2002 Degrees of protection provided by enclosures for electrical equipment against external mechanical impacts (IK code)

BS 1363-2:1995 13A switched and unswitched socket-outlets

and on the basis of this testing, these products are considered to comply with the essential requirements of the following EU Directives:

Support Documentation reference:	10049386 Issue 1	41911A
41911D	9901042B	04013677/01, /02, /03, /04
04013677/05, /17, /18, /19, /20	0406010B	0409005B
2007/019	2007/020	61044
N31423		

Signature: *K. Davis.*

Technical Manager

(GB)



MK Electric

Novar ED&S Limited

Registered Office: Honeywell House, Arlington Business Park, Bracknell, Berkshire RG12 1EB