

DC1126.1

Created on 22/12/2010 10:37:00



DECLARATION OF CONFORMITY

We **Novar ED&S Ltd (MK Electric)**
of **The Arnold Centre, Paycocke Road, Basildon, Essex. UK. SS14 3EA**

Declare under our sole responsibility that the following products:

Masterseal Plus Ingress Protected Switches, 250V a.c., IP66

List No.	Description
K56400 GRY/WHI/BLK	1 gang, SP, 1 way, 10AX
K56401 GRY/WHI/BLK	1 gang, SP, 2 way, 10AX
K56402 GRY/WHI/BLK	2 gang, SP, 1 way, 10AX
K56406 GRY/WHI/BLK	1 gang, DP, 1 way, 10AX
K56407 GRY/WHI/BLK	1 gang, SP, 2 way, push to make/push to break, "Bell", 10A
K56408 GRY/WHI/BLK	1 gang, SP, 2 way, push to make/push to break, "Press", 10A
K56409 GRY/WHI/BLK	1 gang, DP, 1 way, "Press" 20A
K56425 GRY/WHI/BLK	1 gang, DP, 1 way, 20AX, lockable

To which this declaration relates, are in conformity with the test requirements of the following standards:

BS EN 60529:1991 Degrees of protection provided by enclosures (IP code)

BS EN 60669-1:1999 Switches for household and similar fixed electrical installations

and on the basis of this testing, these products are considered to comply with the essential requirements of the following EU Directives:

Low Voltage Directive (2006/95/EC).

CE mark affixed – December 2010

Support Documentation reference:	2007/013	2007/031
2007/034	2007/035	2007/036
2007/037	2009/003	2009/005
38935A	40005321	

Signature: _____

K. Davis.

Technical Manager

(GB)



MK Electric

Novar ED&S Limited

Registered Office: Honeywell House, Arlington Business Park, Bracknell, Berkshire RG12 1EB